

Department of Public Works Infrastructure Services

Ghassan Korban Commissioner of Public Works

Preston D. Cole

Jeffrey S. Polenske City Engineer

May 21, 2012

Subject: Official Notice No. 73

New Chase and High Rise Upgrades Police Administration Building 749 West State Street Milwaukee, Wisconsin

For which bid will be received on Friday, June 1, 2012

Addendum No. 2

Gentlemen:

- A. In regard to our advertisement for the New Chase and High Rise Upgrades at the Police Administration Building, located at 749 W. State Street, Milwaukee, Wisconsin this attached Addendum No. 2 is issued to modify the original documents and is hereby made part of the proposal.
- B. Each bidder shall read the entire addendum. Proposals shall include all items included in this Addendum No. 2.

Very truly yours,

Paul Fredrich, Facilities Manager

Facilities Development & Management Section

Official Notice No. 73

New Chase and High Rise Upgrades Police Administration Building at 749 West State Street Milwaukee, Wisconsin

Addendum No. 2

IMMEDIATELY UPON RECEIPT OF THE ADDENDUM, PLEASE SIGN THIS RECEIPT AND FAX BACK TO ISD – FACILITIES DEVELOPMENT AND MANAGEMENT SECTION AT (414) 286-5907.

Addendum No. 2

May 21, 2012

New Chase and High Rise Upgrades Police Administration Building 749 West State Street Milwaukee, Wisconsin

Specific Official Notice Addendum:

Correction to the Specific Official Notice (web site)

The Specific Official Notice as posted on the DPW web site indicated the incorrect bid opening day and should read "Friday, June 1, 2012".

Add to the Specific Official Notice

THE RESIDENCY REQUIREMENT FOR THIS BRANCH CONTRACT IS 40%

General Conditions Addendum:

Add to the Specifications:

Section 100, Site Visit

There will be a Contractor Walk Thru at the Police Administration Building on Wednesday, May 23, 2012 from 9am-10:30am. Enter the building on the Municipal Courts Floor.

Mechanical Addendum:

HVAC

Changes to the Plans:

- 1. All 48"x30" oval double wall duct risers shall be reduced to 46"x30".
- 2. All 48"x18" oval double wall duct takeoffs shall be reduced to 46"x18".
- 3. Key note #4 on sheet M100 is not used.

Changes to the Specifications:

1. Revise specification 23 31 13 – Metal Ducts section 3.4 to the following:

B. Support vertical ducts at maximum intervals of 5 feet and at each floor level and/or as recommended by manufacturer. Ductwork shall be supported at every flange connection and duct supports shall be only attached to structural steel framing and/or floor slab. Design and detail all supports and connections. The design of all supports and connections is subject to the review and acceptance of the Architect-Engineer. Submit structural calculations prepared and sealed by a qualified engineer registered in the state of Wisconsin. Submit calculations for review before preparation of duct support detail drawings.